



# METRO COTABATO WATER DISTRICT

Gov. Gutierrez Avenue, Cotabato City, P.O. Box 657  
Tel. No. (064) 421-1070; Telefax. No. (064) 421-3009  
Email Add: mcwd\_procurement@yahoo.com



## SUPPLEMENTAL / BID BULLETIN

### ADDENDUM NO. 21-02

#### **“1 Lot – Proposed Design and Build of Modular Compact Water Treatment Facility and Equipment with a Capacity of 8MLD (PR#20-12-0755)”**

This Addendum No. 21-02 is being issued to add, clarify, modify or amend provisions in the Bidding Documents, which shall form an integral part thereof:


ORIGINAL	AMENDMENT
<p><b>Section VI. Specifications (page 89)</b></p> <p><b>6. PIPELINES, INTERCONNECTIONS, AND MANHOLES</b></p> <p><b>A. PIPELINES</b></p> <p>A.2.3. Pipe diameter must be at least 500mm (20”) Ø</p> <p>A.1.4. Thickness: 6.35mm for steel, Cement Coating (CC) -25mm, Cement Lining (CL) – 20mm</p> <p><b>Section VII. Drawings</b></p>	<p><b>Section VI. Specifications (page 89)</b></p> <p><b>6. PIPELINES, INTERCONNECTIONS, AND MANHOLES</b></p> <p><b>A. PIPELINES</b></p> <p>A.2.3. Pipe diameter must be at least 300mmØ (12”Ø)</p> <p>A.1.4. Thickness: 6.35mm for steel, Cement Coating (CC) -25mm, Cement Lining (CL)-(13mm)</p> <p><b>Section VII. Drawings</b></p> <p><b>Sheet #4 and Sheet #9 – See attached file.</b></p>


This Supplemental/Bid Bulletin shall form part of the Bidding Documents. Any provisions in the Bidding Documents inconsistent herewith is hereby amended, modified and superseded accordingly.

For the guidance and information of all concerned.





Issued this 15<sup>th</sup> of January 2021 at Metro Cotabato Water District, Cotabato City, Maguindanao.


Reviewed and approved by:

  
**WINSTON L. SAPAL**  
 BAC - Chairperson *WLS*



<p>PROJECT OF:</p> <p><b>METRO COTABATO WATER DISTRICT</b> GOVERNOR GUTIERREZ AVENUE COTABATO CITY</p>	<p>PROJECT TITLE:</p> <p><b>PROPOSED CONCEPTUAL DESIGN OF MODULAR COMPACT WATER TREATMENT PLANT FACILITY AND EQUIPMENT WITH A CAPACITY OF 8MLD</b></p>	<p>PREPARED BY:</p> <p><b>RANDY M. LINBA</b> DBC-Head / Supervising Engineer A</p>	<p>RECOMMENDING APPROVAL:</p> <p><i>MARGARITA F. ROALES</i> Acting General Manager</p>	<p>APPROVED BY:</p> <p><b>EMILIO A. SIMANAT</b> HOE - BOD Chairman</p>	<p>SHEET CONTENT:</p> <p>Project Site Development Plan, Proposed Tapping Point of Supply Line and Product Line</p>
<p>PROJECT LOCATION:</p> <p>Silo Lambay, Bgy. Awang, D.O.S. Municipality, Maguindanao</p>	<p>SUBMITTED BY:</p> <p><b>GRACIELA M. ARRIETA</b> OIC/BM, Engr. &amp; Maintenance</p>	<p>PROJECT LOCATION:</p>	<p>APPROVED BY:</p>	<p>SHEET CONTENT:</p>	



<p>PROJECT OF:</p>  <p><b>METRO COTABATO WATER DISTRICT</b> GOVERNOR GUTIERREZ AVENUE COTABATO CITY</p>	<p>PROJECT TITLE:</p> <p><b>PROPOSED CONCEPTUAL DESIGN OF MODULAR COMPACT WATER TREATMENT PLANT FACILITY AND EQUIPMENT WITH A CAPACITY OF 8MLD</b></p> <p>PROJECT LOCATION:</p> <p>Silo Lambay, Brgy. Awang, D.O.S. Municipality, Maguindanao</p>	<p>PREPARED BY:</p> <p><b>RANDY MOJESS P. LIMBA</b> DEC-Head / Supervising Engineer A</p> <p>SUBMITTED BY:</p> <p><i>[Signature]</i> <b>GRACIELA MARTINEZ</b> OIC-DM/ Etc. &amp; Maintenance</p>	<p>RECOMMENDING APPROVAL:</p> <p><i>[Signature]</i> <b>MARGARITA E. ROALES</b> Acting- General Manager</p> <p><i>[Signature]</i> <b>EMILIO A. SIMANAT</b> HOPE - BOD Chairman</p>	<p>SHEET CONTENT:</p> <p>Proposed Tapping Point of Supply And Product Line With Interconnection Details</p> <p>SHEET</p> <p><b>9</b></p> <p>OF</p>
--	---	--	---	--