



# METRO COTABATO WATER DISTRICT

Gov. Gutierrez Avenue, Cotabato City, P.O. Box 657

Tel. No. (064) 4211070; Telefax. No. (064) 4213009

Email Add: [mcwd\\_procurement@yahoo.com](mailto:mcwd_procurement@yahoo.com)



## SUPPLEMENTAL / BID BULLETIN

### ADDENDUM NO. 22-05

#### “Supply and Delivery of 1 Lot Various Materials and Fittings” (PR#22-08-0528)”

This Addendum No. 22-05 is being issued to add, clarify, modify or amend provisions in the Bidding Documents, which shall form an integral part thereof:

ORIGINAL	AMENDMENT
<b>Section VIII. Technical Specifications</b>  <b>Potable Water Pressure Main Main Distribution System uPVC Pipes-PNS 65 (page 31)</b>  <b>uPVC Fittings (page 32)</b>	<b>Section VIII. Technical Specifications</b>  <b>Please see attached Specifications for uPVC Pipes – PNS – 65 and uPVC ELBOW</b>

This Supplemental/Bid Bulletin shall form part of the Bidding Documents. Any provisions in the Bidding Documents inconsistent herewith is hereby amended, modified and superseded accordingly.


For the guidance and information of all concerned.

Issued this 31<sup>st</sup> of August 2022 at Metro Cotabato Water District, Cotabato City, Maguindanao.

Reviewed and approved by:

  
**WINSTON L. SAPAL**  
BAC Chairperson

## SPECIFICATIONS:



### uPVC Pipes-PNS 65

Specification: PNS 65:1963  
 Color: Blue (RAL 5012)  
 Jointing Method: PUSH-ON TYPE (REMOVABLE GASKET)

Nominal Size		Outside Diameter of Pipe	Effective Length	Wall Thickness-T (mm) Series 8 (C-150)	
inches	mm			min	max
6	150	160	6000	9.2	10.32

### uPVC ELBOW



uPVC Elbow 90°



uPVC Elbow 45°



uPVC Elbow 22.5°

Jointing Method (for elbow): INTEGRAL FIXED SEAL TYPE

A handwritten signature in black ink, located in the bottom right corner of the page.