



METRO COTABATO WATER DISTRICT

Gov. Gutierrez Avenue, Cotabato City, P.O. Box 657

Tel. No. (064) 4211070; Telefax. No. (064) 4213009

Email Add: mcwd_procurement@yahoo.com



SUPPLEMENTAL / BID BULLETIN

ADDENDUM NO. 23-03

“1 Lot - Supply, Laboratory Pump Test, Installation and Commissioning of Two (2) sets Brand New Vertical Turbine Pump for Dimapatoy Pumping Station (PR#23-03-0187)”

This Addendum No. 23-03 is being issued to add, clarify, modify or amend provisions in the Bidding Documents, which shall form an integral part thereof:

ORIGINAL	AMENDMENT
<p>Section VII. Technical Specifications (page 29)</p> <p>Line Shaft: Stainless Steel No. 316 x 1 ½”Ø With one coupling SS-316 for each shaft, 1 pc. 1 ½” x 38” L 1 pc. 1 ½” x 60” L 2 pcs. 1 ½” x 120”L 1 pc. 1 ½” 53” Top Shaft with Key Way and 2 pcs. Lock Nut All shafts must be dynamically aligned.</p>	<p>Section VII. Technical Specifications (page 29)</p> <p>Line Shaft: Stainless Steel No. 316 x 1 ½”Ø With one coupling SS-316 for each shaft, 1 pc. 1 ½”Ø x 38” L 1 pc. 1 ½”Ø x 60” L 2 pcs. 1 ½”Ø x 120”L 1 pc. 1 ½”Ø x 53” Top Shaft with Key Way and 2 pcs. Lock Nut All shafts must be dynamically aligned.</p>

This Supplemental/Bid Bulletin shall form part of the Bidding Documents. Any provisions in the Bidding Documents inconsistent herewith is hereby amended, modified and superseded accordingly.

For the guidance and information of all concerned.

Issued this 13th of April 2023 at Metro Cotabato Water District, Cotabato City, Maguindanao.

Reviewed and approved by:



JOSELITO D. NUÑEZ, JR.
 BAC - Chairperson

1413

