



METRO COTABATO WATER DISTRICT

Gov. Gutierrez Avenue, Cotabato City, P.O. Box 657

Tel. No. (064) 4211070; Telefax. No. (064) 4213009

Email Add: mcwd_procurement@yahoo.com



SUPPLEMENTAL / BID BULLETIN

ADDENDUM NO. 23-11

“Supply and Delivery of 1,875 pieces Water Meter 15mm (PR#23-07-0421)”

This Addendum No. 23-11 is being issued to add, clarify, modify or amend provisions in the Bidding Documents, which shall form an integral part thereof:


ORIGINAL	AMENDMENT
<p>Section VII. Technical Specifications</p> <p>I. Technical Specifications: (page 29)</p> <p>4. Meter Body: Copper alloy containing not less than 75% copper or a Copper Alloy containing not less than 57% copper but with anti-corrosion treatment.</p> <p>Shall submit 2023 Certification from DOST-MIRDC material testing laboratory during the Bid Opening.</p>	<p>Section VII. Technical Specifications</p> <p>I. Technical Specifications: (page 29)</p> <p>4. Meter Body: Copper alloy containing not less than 75% copper or a Copper Alloy containing not less than 57% copper but with anti-corrosion treatment.</p> <p>Shall submit 2023 Certification from DOST-MIRDC material testing laboratory during the Post-Qualification.</p>

This Supplemental/Bid Bulletin shall form part of the Bidding Documents. Any provisions in the Bidding Documents inconsistent herewith is hereby amended, modified and superseded accordingly.

For the guidance and information of all concerned.

Issued this 17th of August 2023 at Metro Cotabato Water District, Cotabato City, Maguindanao.

Reviewed and approved by:


FULVIO R. TUMAYAO
BAC – Vice-Chairperson

18/17

