



METRO COTABATO WATER DISTRICT

Gov. Gutierrez Avenue, Cotabato City, P.O. Box 657
Tel. No. (064) 4211070; Telefax. No. (064) 4213009
Email Add: mcwd_procurement@yahoo.com



SUPPLEMENTAL / BID BULLETIN

ADDENDUM NO. 23-12

“Supply, Laboratory Pump Test, Delivery, Installation & Commissioning of One (1) lot Brand New 175HP Submersible Polder Pump with Wye-Delta Reduce Voltage Magnetic Starter, Riser Pipes & Submersible Cables for Dimapatoy (Collectors Well) Pump Station (PR#23-08-0466)”

This Addendum No. 23-12 is being issued to add, clarify, modify or amend provisions in the Bidding Documents, which shall form an integral part thereof:

ORIGINAL	AMENDMENT
<p>Title:</p> <p>Supply, Laboratory Pump Test, Delivery, Installation & Commissioning of One (1) lot Brand New 175HP Polder Pump with Wye-Delta Reduce Voltage Magnetic Starter, Riser Pipes & Submersible Cables for Dimapatoy (Collectors Well) Pump Station</p> <p>Section I. Invitation to Bid (page 6)</p> <p>Invitation to Bid for Supply, Laboratory Pump Test, Delivery, Installation & Commissioning of One (1) lot Brand New 175HP Polder Pump with Wye-Delta Reduce Voltage Magnetic Starter, Riser Pipes & Submersible Cables for Dimapatoy (Collectors Well) Pump Station</p> <p>1. The Metro Cotabato Water District (MCWD), through the MCWD 2023 Corporate Budget approved by Board of Directors intends to apply the sum of Two Million Nine Hundred Forty Thousand Pesos (PhP2,940,000.00) being the ABC to payments under the contract for Supply, Laboratory Pump Test, Delivery, Installation & Commissioning of One (1) lot Brand New 175HP Polder Pump with Wye-Delta Reduce Voltage Magnetic Starter, Riser Pipes & Submersible Cables for Dimapatoy (Collectors Well) Pump Station (PR#23-08-0466). Bids received in excess of the ABC shall be automatically rejected at bid opening.</p> <p>Section II. Instructions to Bidders (page 9)</p> <p>1. Scope of Bid The Procuring Entity, Metro Cotabato Water District wishes to receive Bids for the Supply, Laboratory Pump Test, Delivery, Installation & Commissioning of One (1) lot Brand New 175HP Polder Pump with Wye-Delta Reduce Voltage Magnetic Starter, Riser Pipes & Submersible Cables for Dimapatoy (Collectors Well) Pump Station (PR#23-08-0466).</p>	<p>Title:</p> <p>Supply, Laboratory Pump Test, Delivery, Installation & Commissioning of One (1) lot Brand New 175HP Submersible Polder Pump with Wye-Delta Reduce Voltage Magnetic Starter, Riser Pipes & Submersible Cables for Dimapatoy (Collectors Well) Pump Station</p> <p>Section I. Invitation to Bid (page 6)</p> <p>Invitation to Bid for Supply, Laboratory Pump Test, Delivery, Installation & Commissioning of One (1) lot Brand New 175HP Submersible Polder Pump with Wye-Delta Reduce Voltage Magnetic Starter, Riser Pipes & Submersible Cables for Dimapatoy (Collectors Well) Pump Station</p> <p>1. The Metro Cotabato Water District (MCWD), through the MCWD 2023 Corporate Budget approved by Board of Directors intends to apply the sum of Two Million Nine Hundred Forty Thousand Pesos (PhP2,940,000.00) being the ABC to payments under the contract for Supply, Laboratory Pump Test, Delivery, Installation & Commissioning of One (1) lot Brand New 175HP Submersible Polder Pump with Wye-Delta Reduce Voltage Magnetic Starter, Riser Pipes & Submersible Cables for Dimapatoy (Collectors Well) Pump Station (PR#23-08-0466). Bids received in excess of the ABC shall be automatically rejected at bid opening.</p> <p>Section II. Instructions to Bidders (page 9)</p> <p>1. Scope of Bid The Procuring Entity, Metro Cotabato Water District wishes to receive Bids for the Supply, Laboratory Pump Test, Delivery, Installation & Commissioning of One (1) lot Brand New 175HP Submersible Polder Pump with Wye-Delta Reduce Voltage Magnetic Starter, Riser Pipes & Submersible Cables for Dimapatoy (Collectors Well) Pump Station (PR#23-08-0466).</p>



METRO COTABATO WATER DISTRICT

Gov. Gutierrez Avenue, Cotabato City, P.O. Box 657
Tel. No. (064) 4211070; Telefax. No. (064) 4213009
Email Add: mcwd_procurement@yahoo.com



ORIGINAL	AMENDMENT
<p>The Procurement Project (referred to herein as “Project”) is composed of Supply and Supply, Laboratory Pump Test, Delivery, Installation & Commissioning of One (1) lot Brand New 175HP Polder Pump with Wye-Delta Reduce Voltage Magnetic Starter, Riser Pipes & Submersible Cables for Dimapatoy (Collectors Well) Pump Station, the details of which are described in Section VII (Technical Specifications).</p> <p>Section III. Bid Data Sheet (page 16)</p> <p>ITB Clause 19.3 Supply, Laboratory Pump Test, Delivery, Installation & Commissioning of One (1) lot Brand New 175HP Polder Pump with Wye-Delta Reduce Voltage Magnetic Starter, Riser Pipes & Submersible Cables for Dimapatoy (Collectors Well) Pump Station</p> <p>Section VI. Schedule of Requirements (page 26)</p> <p>Description: Supply, Laboratory Pump Test, Delivery, Installation & Commissioning of One (1) lot Brand New 175HP Polder Pump with Wye-Delta Reduce Voltage Magnetic Starter, Riser Pipes & Submersible Cables for Dimapatoy (Collectors Well) Pump Station</p> <p>Section VII. Technical Specifications (page 29)</p> <p>Supply, Laboratory Pump Test, Delivery, Installation & Commissioning of One (1) lot Brand New 175HP Polder Pump with Wye-Delta Reduce Voltage Magnetic Starter, Riser Pipes & Submersible Cables for Dimapatoy (Collectors Well) Pump Station</p> <p>I. Technical Specifications</p> <p>A. Polder Pump/Motor</p> <p>II. Terms and Conditions:</p> <p>2. All required manpower, equipment, materials and other incidentals shall be provided by the supplier during the delivery pump test, installation and commissionin,</p>	<p>The Procurement Project (referred to herein as “Project”) is composed of Supply and Supply, Laboratory Pump Test, Delivery, Installation & Commissioning of One (1) lot Brand New 175HP Submersible Polder Pump with Wye-Delta Reduce Voltage Magnetic Starter, Riser Pipes & Submersible Cables for Dimapatoy (Collectors Well) Pump Station, the details of which are described in Section VII (Technical Specifications).</p> <p>Section III. Bid Data Sheet (page 16)</p> <p>ITB Clause 19.3 Supply, Laboratory Pump Test, Delivery, Installation & Commissioning of One (1) lot Brand New 175HP Submersible Polder Pump with Wye-Delta Reduce Voltage Magnetic Starter, Riser Pipes & Submersible Cables for Dimapatoy (Collectors Well) Pump Station</p> <p>Section VI. Schedule of Requirements (page 26)</p> <p>Description: Supply, Laboratory Pump Test, Delivery, Installation & Commissioning of One (1) lot Brand New 175HP Submersible Polder Pump with Wye-Delta Reduce Voltage Magnetic Starter, Riser Pipes & Submersible Cables for Dimapatoy (Collectors Well) Pump Station</p> <p>Section VII. Technical Specifications (page 29)</p> <p>Supply, Laboratory Pump Test, Delivery, Installation & Commissioning of One (1) lot Brand New 175HP Submersible Polder Pump with Wye-Delta Reduce Voltage Magnetic Starter, Riser Pipes & Submersible Cables for Dimapatoy (Collectors Well) Pump Station</p> <p>I. Technical Specifications</p> <p>A. Submersible Polder Pump/Motor</p> <p>II. Terms and Conditions:</p> <p>2. All required manpower, equipment, materials and other incidentals shall be provided by the supplier during the delivery pump test, installation and commissioning,</p>





METRO COTABATO WATER DISTRICT

Gov. Gutierrez Avenue, Cotabato City, P.O. Box 657
Tel. No. (064) 4211070; Telefax. No. (064) 4213009
Email Add: mcwd_procurement@yahoo.com




This Supplemental/Bid Bulletin shall form part of the Bidding Documents. Any provisions in the Bidding Documents inconsistent herewith is hereby amended, modified and superseded accordingly.

For the guidance and information of all concerned.

Issued this 24th of August 2023 at Metro Cotabato Water District, Cotabato City, Maguindanao.

Reviewed and approved by:


JOSELITO D. NUÑEZ, JR.
BAC – Chairperson

