

SUPPLEMENTAL / BID BULLETIN

Correction on Technical Specifications

“Supply, Delivery, Installation, Commissioning of One (1) Unit Brand New Close/Silent Type Diesel Generator Set (Genset) 315KVA (PB-0003-2018)”

This correction dated March 15, 2018 is issued to clarify, modify or amend items in the Bidding Documents, which shall form an integral part thereof:

ISSUES	CLARIFICATIONS / AMENDMENTS
<p>SECTION VII. Technical Specifications (page 55)</p> <p>ID – Fuel Tank:</p> <p>Initial Content: Can operate the Genset at 8 hrs. Continues operation During testing (To be supplied by the supplier)</p> <p>Installation: Separate from the Genset with external fuel pipe lines & base (See Attached Drawing)</p> <p>IE – Electrical Connection: (See Attached Drawings)</p> <p>Transfer Switch: Rated Manual Transfer Switch</p> <p>Inclusive Lines: 3. From Genset 3 to MTS3 & MTS4</p>	<p>SECTION VII. Technical Specifications (page 55)</p> <p>ID – Fuel Tank:</p> <p>Initial Content: Can operate the Genset at 8 hrs. Continues operation With load During testing (To be supplied by the supplier)</p> <p>Installation: Skid Mounted or Separate from the Genset with external fuel pipe lines & base (See Attached Drawing)</p> <p>IE – Electrical Connection: (See Attached Drawings)</p> <p>Transfer Switch: 2 units Rated Manual Transfer Switch</p> <p>Inclusive Lines: 3. From Genset 3 to MTS3 & Genset 3 to MTS4</p> <p>IF - FILTERS: Spare (One each type)</p> <p>1. Oil Filter</p> <p>2. Fuel Filter</p> <p>3. Air Cleaner</p> <p>IG – Sound Reduction: Muffler & Attenuated Sound Enclosure</p>

For guidance and information of all concerned.

VENANCIO E. VILLARMA, JR.

BAC - Chairman

Received by the Bidder: _____

Date: _____