



METRO COTABATO WATER DISTRICT

Gov. Gutierrez Avenue, Cotabato City, P.O. Box 657
Tel. No. (064) 4211070; Telefax. No. (064) 4213009
Email Add: mcwd_procurement@yahoo.com



SUPPLEMENTAL / BID BULLETIN

ADDENDUM NO. 20-03

“Furnishing of materials, labor, tools and equipment for the Replacement of Existing 400mmØ Steel Transmission Mains to 400mm Ø Ductile Iron Pipes and Fittings from Taniel Pumping Station to SPDA Road Junction”

OCB No.: WDDSP-MCWD-OCB-CW12

This Addendum No. 20-03 is being issued to add, clarify, modify or amend provisions in the Bidding Documents, which shall form an integral part thereof:


ORIGINAL	AMENDMENT
<p>Section VI. Specifications</p> <p>2.0 DUCTILE-IRON PIPE</p> <p>a. General</p> <p>XXXX</p>	<p>Section VI. Specifications</p> <p>2.0 DUCTILE-IRON PIPE</p> <p>a. General</p> <p>XXXX</p> <p>Add the following as 2nd paragraph:</p> <p>ISO Standard Ductile Iron Pipes, 400mmØ x 6.00M. x 8.10mm thick (K9 class) shall be allowed to be used by the Contractor provided that ADAPTORS to connect the existing AWWA Standard Piping System shall be supplied by the Contractor and the corresponding costs shall be part of its Contract amount.</p>

This Supplemental/Bid Bulletin shall form part of the Bidding Documents. Any provisions in the Bidding Documents inconsistent herewith is hereby amended, modified and superseded accordingly.

For the guidance and information of all concerned.

Issued this 18th of November 2020 at Metro Cotabato Water District, Cotabato City, Maguindanao.

Reviewed and approved by:


WINSTON L. SAPAL
 BAC - Chairperson *WLS*