



METRO COTABATO WATER DISTRICT

Gov. Gutierrez Avenue, Cotabato City, P.O. Box 657

Tel. No. (064) 4211070; Telefax. No. (064) 4213009

Email Add: mcwd_procurement@yahoo.com



SUPPLEMENTAL / BID BULLETIN

ADDENDUM NO. 21-10

"Supply and Delivery of 6,300 pieces Water Meter 1/2" (15mm) PR#21-08-0510"

This Addendum No. 21-10 is being issued to add, clarify, modify or amend provisions in the Bidding Documents, which shall form an integral part thereof:

ORIGINAL	AMENDMENT
<p>Section VII. Technical Specifications (page 27)</p> <p>4. Meter Body: Copper alloy containing not less than 75% copper or a Copper Alloy containing not less than 57% copper but with anti-corrosion treatment. Shall submit 2021 Certification from DOST-MIRDC material testing laboratory during the Bid Opening but required to submit the 2021 Certification during the Post-Qualification evaluation.</p> <p>5. Register:</p> <ul style="list-style-type: none"> - Hermetically vacuum sealed. - Magnetically driven sealed register for fraud protection. - Hermetically sealed encapsulated stainless steel capsule/dome type - Clear glass lens tempered high impact lens and abrasion resistant. - Meter register in Cubic Meters with a minimum of five (5) digits. - Straight Reading Meter capacity should be placed preceded by the letter "N" or "Qn" <p>Terms and Conditions (page 29)</p> <p>1. Bidder must submit a Prototype Sample of Water Meter 1/2", plastic lens with tailpiece (1 whole and 1 cut-away) and attach brochure of their offer during bid-opening for evaluation.</p> <p>17. Packaging: 6. Box – Each box shall contain 10 pieces of Water Meters and indicate the correct series of serial numbers with its control number below. Example: 22-36117 to 22-36126 Box No. 1</p>	<p>Section VII. Technical Specifications (page 27)</p> <p>4. Meter Body: Copper alloy containing not less than 75% copper or a Copper Alloy containing not less than 57% copper but with anti-corrosion treatment. Shall submit 2020 Certification from DOST-MIRDC material testing laboratory during the Bid Opening but required to submit the 2021 Certification during the Post-Qualification evaluation.</p> <p>5. Register:</p> <ul style="list-style-type: none"> - Hermetically vacuum sealed. - Magnetically driven sealed register for fraud protection. - Hermetically sealed encapsulated steel / brass capsule - Clear glass lens tempered high impact lens and abrasion resistant. - Meter register in Cubic Meters with a minimum of five (5) digits. - Straight Reading Meter capacity should be placed preceded by the letter "N" or "Qn" - Replaceable Registry Assembly / Replaceable Insert Assembly <p>Terms and Conditions (page 29)</p> <p>1. Bidder must submit a Prototype Sample of Water Meter 1/2" (15mm), glass lens with tailpiece (1 whole and 1 cut-away) and attach brochure of their offer during bid-opening for evaluation.</p> <p>17. Packaging: 6. Box – each box shall contain 10 pieces of Water Meters and indicate in each box the correct number series of Serial numbers with its control number below. Example: 1) Box No. 1 – Serial Nos. – 22-36117 to 22-36127 (10 pcs. Water Meters)</p>

Water Conserved Today is Water Abundant Tomorrow





METRO COTABATO WATER DISTRICT

Gov. Gutierrez Avenue, Cotabato City, P.O. Box 657

Tel. No. (064) 4211070; Telefax. No. (064) 4213009

Email Add: mcwd_procurement@yahoo.com




	<p>2) Box No. 2 – Serial Nos. – 22-36128 to 22-36138 (10 pcs. – Water Meters)</p> <p>3) Box No. 3 – Serial Nos. – 22-36139 to 22-36149 (10 pcs. – Water Meters) and so on..</p> <p>Note: Failure of the supplier to comply the above requirements, the overtime pay of the MCWD Personnel who will arrange the sequence of the boxes and the serial numbers shall be shouldered by the supplier.</p>
--	--

This Supplemental/Bid Bulletin shall form part of the Bidding Documents. Any provisions in the Bidding Documents inconsistent herewith is hereby amended, modified and superseded accordingly.

For the guidance and information of all concerned.

Issued this 15th of September, 2021 at Metro Cotabato Water District, Cotabato City, Maguindanao.

Reviewed and approved by:


WINSTON L. SAPAL
BAC Chairperson
