



METRO COTABATO WATER DISTRICT

Gov. Gutierrez Avenue, Cotabato City, P.O. Box 657

Tel. No. (064) 4211070; Telefax. No. (064) 4213009

Email Add: mcwd_procurement@yahoo.com



SUPPLEMENTAL / BID BULLETIN

ADDENDUM NO. 22-02

“Supply, Delivery and Commissioning of the Leak Detection Equipment (1 set – Real Time Correlator and 1 set – Ground Microphone for Pinpointing Leak) (PR#22-07-0522)”

This Addendum No. 22-02 is being issued to add, clarify, modify or amend provisions in the Bidding Documents, which shall form an integral part thereof:

ORIGINAL	AMENDMENT
<p>Section VII. Technical Specifications (page 28)</p> <p>A. 1 set – Real Time Correlator</p> <p>Receiver</p> <p>Radio frequency range: 407 – 472MHZ Battery: 7.2VDC 3.2Ah 23-25Wh –not user replaceable Battery operating time: 7 hours approx. Dimensions: 135mm x 138mm x 36mm Altitude: 2000m max</p>	<p>Section VII. Technical Specifications (page 28)</p> <p>A. 1 set – Real Time Correlator</p> <p>Receiver</p> <p>Radio frequency range: 407 – 472MHZ Battery: 7.2VDC 3.2Ah 23-25Wh –not user replaceable Battery operating time: 7 hours approx. Dimensions: 135mm x 138mm x 36mm (maximum) Altitude: 2000m max</p>

This Supplemental/Bid Bulletin shall form part of the Bidding Documents. Any provisions in the Bidding Documents inconsistent herewith is hereby amended, modified and superseded accordingly.

For the guidance and information of all concerned.

Issued this 18th of August 2022 at Metro Cotabato Water District, Cotabato City, Maguindanao.

Reviewed and approved by:


JOCELYN A. PLAZOS
 BAC – Vice-Chairperson



